

OUTSIDE REFERRAL AGENCY MATRIX

PROJECT: Valley Feed Filing No. 1 CASE NO. PP17-0001; FP17-0001

DATE REFERRALS SENT: September 1, 2017

AGENCY	DATE RECEIVED	COMMENTS
CenturyLink		No response received. Provided a will-serve letter with the initial application.
Denver Water		Provided a will-serve letter with the initial application
Xcel Energy		Provided a will-serve letter with the initial application and also provided pertaining to relocation of existing facilities and siting of new facilities. <i>The utility locations will be finalized with the site development plan and any necessary utility easements will be recorded by separate instrument.</i>
Arapahoe County		No response received.
Tri-County Health	September 27, 2017	Provided a “no comment” response letter.
Littleton/Englewood Wastewater Treatment Plant	September 26, 2017	Provided information pertaining to the connection to the sanitary sewer which will need to be further evaluated. The LEWWTP also stated that a pre-treatment device may be required, depending on the future use (food service businesses require a gravity grease interceptor; parking garages and elevators require sand/oil interceptors if connected to the sanitary sewer). <i>The connection to the sanitary sewer and the need for any additional pre-treatment devices will be addressed with the Site Development Plan application.</i>