

OUTSIDE REFERRAL AGENCY MATRIX

PROJECT:

CASE NO.

DATE REFERRALS SENT:

| AGENCY | DATE RECEIVED | COMMENTS |
|--|---------------|--|
| CenturyLink | 4/19/2018 | No conflict |
| Denver Water | 1/19/2018 | Provided their Standard Notes for Development Services Concept Review |
| Xcel Energy | 4/18/2018 | No conflict, reminds the property owner/developer/contractor to complete the application process for any new natural gas or electric service, or modification to existing facilities |
| Urban Drainage & Flood Control District | 2/9/2018 | 1. The proposed 12-inch pipe outfall to Drainageway D appears acceptable. 2. It is our understanding that the applicant wants to change the access road surface from concrete to a native grass surface. We will accept a reinforced grass surface as shown on Figure FG-1 in the Urban Storm Drainage Criteria Manual, Volume 3. |
| Town of Columbine Valley | 1/23/2018 | No objection |
| Platte Canyon Water & Sanitation District | 6/9/2017 | Indicated that the water and sewer are in the City of Littleton's jurisdiction, but noted that according to a sewer tap agreement between Littleton and Platte Canyon, the number of sewer taps onto Platte Canyon's main is limited. |